

**GE Site
Yearly Performance Evaluation
GE Ovation 0.35
24-Oct-07**

Table of Contents

Summary and Signature Page	2
Specific Comments	3
Site Information	4
Equipment Information	4
Table Position Accuracy	4
Magnetic Field Homogeneity	4
Slice Thickness Accuracy	4
Slice Crosstalk	5
Soft Copy Displays	6
RF Coil Performance Evaluation	
Coil Inventory List	7
Body - Access Open	8
Body - Integrated	10
CTL Phased Array	11
Foot	17
Head	18
Knee - Large	19
Knee & Foot (Small)	21
Shoulder Phased Array	23
Appendix A: Magnet Homogeneity Map	24
Appendix B: Slice Thickness / Profiles / RF Crosstalk	28
Appendix C: ACR Phantom Analysis	30
Appendix D: Explanation of RF Coil Test Format	37

MRI Equipment Evaluation Summary & Signature Page

Site Name: <u>GE Site</u>	MRAP # <u>03292-01</u>
Address: _____	Survey Date: <u>10/24/07</u>
City, State, Zip _____	Report Date: <u>11/20/07</u>
MRI Mfg: <u>GE</u>	Model: <u>Ovation</u>
	Field: <u>0.35</u>
MRI Scientist: <u>Moriel NessAiver, Ph.D.</u>	Signature: <u><i>Moriel NessAiver, Ph.D.</i></u>

Equipment Evaluation Tests

- | | Pass | Fail * | N/A |
|---|-------------------------------------|--------------------------|--------------------------|
| 1. Magnetic field homogeneity: | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 2. Slice position accuracy: | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 3. Table positioning reproducibility: | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 4. Slice thickness accuracy: | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 5. RF coils' performance: | | | |
| a. Volume QD Coils | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| b. Phase Array Coils | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| c. Surface Coils | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 6. Inter-slice RF interference (Crosstalk): | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 7. Soft Copy Display | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |

Evaluation of Site's Technologist QC Program

- | | Pass | Fail * | N/A |
|--|-------------------------------------|--------------------------|--------------------------|
| 1. Set up and positioning accuracy: (daily) | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 2. Center frequency: (daily) | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 3. Transmitter attenuation or gain: (daily) | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 4. Geometric accuracy measurements: (daily) | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 5. Spatial resolution measurements: (daily) | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 6. Low contrast detectability: (daily) | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 7. Head Coil SNR (daily) | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 8. Body Coil SNR (weekly) | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 9. Fast Spin Echo (FSE/TSE) ghosting levels: (daily) | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 10. Film quality control: (weekly) | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 11. Visual checklist: (weekly) | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |

*See comments page for description of any failures.

MRI Equipment Performance Evaluation Data Form

Site Name: GE Site

Contact	Title	Phone	Fax	eMail
	Chief Tech			

Equipment Information

MRI Manufacturer: GE Model: Ovation SN: _____ Software: MFO.2_M.4.0220
 Camera Manufacturer: AGFA Model: Drystar 3000 SN: _____ Software: _____
 PACS Manufacturer: _____ Model: _____ SN: _____ Software: _____
 ACR Phantom Number used: J2664

1. Table Positioning Reproducibility:

Pass

Table motion out/in: _____

IsoCenter	Out/In	Out/In	Out/In
-2.5	-2.3	-2.3	-2.3

Measured Phantom Center

Comment: _____

2. Magnetic Field Homogeneity

See appendix A for field plots.

PASS

Last Year CF: 14855078 This Year CF: 14850733 CF Change: -4345

GRE TR: 500, TE: 10 & 30 Flip Angle: 45, FOV: 40

10 mm skip 10 mm, BW: 10.4KHz, 256x128, 2nex

	15 cm	20 cm	25 cm
Axial:	9.5	14.3	19.9
Coronal:	3.4	4.9	7.1
Sagittal:	10.1	14.8	20.0

Comments: The shim in the coronal direction is very good. The axial and sagittal shims suffer from inhomogeneity in the posterior portion of the field.

3. Slice Thickness Accuracy

FOV: 250mm Matrix: 256x256 (Slice #1 from ACR Phantom) All values in mm

Sequence	TR	TE	Flip	NSA	Calc	Target	% Error
SE (ACR)	500	20	90	1	5.49	5	9.8%
SE (20/80)	2000	20	90	1	5.50	5	10.0%
SE (20/80)	2000	80	90	1	5.00	5	0.0%
SE (Site T1)	500	14	90	1	5.55	5	11.0%
FSE(16)	3000	80	90	1	5.47	5	9.4%

Comments: _____


4. Slice Crosstalk (RF interference)

The following data were obtained using the ACR phantom slice thickness wedges to measure the slice profile of a two T1 weighted sequences when the slice gap varies from 200% down to 0% (contiguous). As the slices get closer together it is expected that the edges of the slices will overlap causing a deterioration of the slice profile. The data shown below clearly demonstrates this effect. The POMP sequence shows a stable slice thickness until the slice gap drops below 20%. The normal SE sequence has a rather strange curve. I'm not sure what is happening with the slice gaps above 35% but there is no question that there is crosstalk at 35% and lower.

All of the slice profiles can be seen in Appendix B.

Sequence Type	TR	TE	FOV (cm ²)	Matrix	NSA	Thickness	# of slices	Slice Measured
SE	400	18	25	256x256	2	5	11	6
POMP	400	19	25	256x256	2	5	12	6

Skip	SE	POMP
0	4.52	4.3
0.2	4.44	4.47
0.5	4.54	4.74
1	4.65	4.95
1.5	4.93	4.98
2	5.02	5.02
2.5	4.91	5.06
5	5.47	5.09
10	5.54	5.07



5. Soft & Hard Copy Displays

Luminance Meter Make/Model: Tektronix J16 Digital Photometer

Cal Expires: 4/6/06

Monitor Description: LCD

Luminance Measured: Ft. lamberts

Measured Data					
Which Monitor	Center of Image Display	Top Left Corner	Top Right Corner	Bottom Left Corner	Bottom Right Corner
Console	49	40.8	44.2	45.8	46.2

Uniformity		
MAX	MIN	Percent Delta
49	40.8	18%


SMPTE
OK?
Y

$\% \text{ delta} = 200\% \times (\text{max} - \text{min}) / (\text{max} + \text{center})$ (>30% is action limit)

Minimum Brightness must be > 26.24 Ft. Lamberts

Monitor and film - both look good.

Density	Ft-Lambert	Film Density
0	0.29	-2.95
5	0.49	-2.4
10	0.79	-2.1
20	1.80	-1.59
30	3.56	-1.27
40	5.63	-1.03
50	8.82	-0.84
60	13.31	-0.72
70	20.2	-0.57
80	28.8	-0.44
90	36.9	-0.34
95	41.7	-0.27
100	48.6	-0.23



RF Coil Performance Evaluation

Coil: Body - Access Open

Mfg.: USA Inst.

Mfg. Date: 4/1/2002 Coil ID: 239

Phantom: Body sphere



Test Date: 10/24/2007

Model: 10221

Revision: A

SN: 348

of Channels 1


Sequence	TR	TE	Plane	FOV	Nx	Ny	BW	NSA	Thickness	Gap
SE	300	20	T	40	256	256	10.4	1	5	-

Coil Mode: Access Body

TX gain: 185 R1: 11 R2: 30

Analysis of Test Image

Measured Data							Calculated Results			
Label	Mean	Max	Min	Back ground	Noise SD	Noise Type	Mean SNR	Normal-ized	Max SNR	Uni-formity
N	3,021	4,362	2,691	10.0	85.00	NEMA	25.1	6.9	36.3	76.3%
A	3,011	4,318	2,661	139.6	74.65	Air	26.4	7.3	37.9	76.3%



RF Coil Performance Evaluation

Coil: Body - Access Open

Mfg.: USA Inst.

Mfg. Date: 4/1/2002 Coil ID: 239

Phantom: _____



Test Date: 10/24/2007

Model: 10221

Revision: A

SN: 348

of Channels 1

Sequence	TR	TE	Plane	FOV	Nx	Ny	BW	NSA	Thickness	Gap
SE	500	25	T	35	256	128	10.4	1	5	-


Coil Mode: Access Body

TX gain: 186 R1: 11 R2: 30

Analysis of Test Image

Measured Data							Calculated Results			
Label	Mean	Max	Min	Back ground	Noise SD	Noise Type	Mean SNR	Normal-ized	Max SNR	Uni-formity
2007	3,324	5,404	2,938	11.4	85.08	NEMA	27.6	5.0	44.9	70.4%
2006	3,351	5,792	2,965	10.2	82.80	NEMA	28.6	5.2	49.5	67.7%

This is the USA Test protocol. When using my NEMA method of calculating the SNR, the spec should be greater than .66. In 2005 it passed. In 2006 it failed. Current images are virtually identical to 2006. The images are noticeably noisier than 2005. (The images on the left below is from 2007, on the right is from 2006).



RF Coil Performance Evaluation

Coil: Body - Integrated

Mfg.: GE

Mfg. Date: _____ Coil ID: 242

Phantom: 27 cm sphere in loading ring.



Test Date: 10/24/2007

Model: _____

Revision: _____

SN: _____

of Channels 1


Sequence	TR	TE	Plane	FOV	Nx	Ny	BW	NSA	Thickness	Gap
SE	300	20	T	40	256	128	10.4	4	5	-

Coil Mode: Body

TX gain: 189 R1: 11 R2: 29

Analysis of Test Image

Measured Data							Calculated Results			
Label	Mean	Max	Min	Back ground	Noise SD	Noise Type	Mean SNR	Normal-ized	Max SNR	Uni-formity
N	957	1,113	723	6.9	32.23	NEMA	21.0	1.4	24.4	78.8%
A	951	1,127	716	51.3	27.19	Air	22.9	1.6	27.2	77.7%



RF Coil Performance Evaluation



Test Date: 10/24/2007
 Model: 100216
 Revision: A
 SN: 365
 # of Channels 6

Coil: CTL Phased Array

Mfg.: USA Inst.

Mfg. Date: 7/10/2007 Coil ID: 795

Phantom: CTL Phantoms (no pad)

Sequence	TR	TE	Plane	FOV	Nx	Ny	BW	NSA	Thickness	Gap
SE	500	25	S	40	256	256	10.4	1	5	-


Coil Mode: a Cervical - Postioned @ i0 mark

TX gain: 189 R1: 7 R2: 29

Analysis of Test Image

Measured Data							Calculated Results			
Label	Mean	Max	Min	Back ground	Noise SD	Noise Type	Mean SNR	Normal-ized	Max SNR	Uni-formity
2007	884	1,752	218	1.4	7.21	NEMA	86.7	23.9	171.8	22.1%
2006	1,725	2,733	520	3.8	15.43	NEMA	79.1	21.8	125.3	32.0%

Uses gradient distortion correction.



RF Coil Performance Evaluation



Test Date: 10/24/2007
 Model: 100216
 Revision: A
 SN: 365
 # of Channels 6

Coil: CTL Phased Array

Mfg.: USA Inst.

Mfg. Date: 7/10/2007 Coil ID: 795

Phantom: CTL phantoms

Sequence	TR	TE	Plane	FOV	Nx	Ny	BW	NSA	Thickness	Gap
SE	300	20	S	40	256	256	10.4	1	5	-

Coil Mode: b Cervical - Location @ i65


TX gain: 188 R1: 7 R2: 29

Analysis of Composite Image


Measured Data							Calculated Results			
Label	Mean	Max	Min	Back ground	Noise SD	Noise Type	Mean SNR	Normal-ized	Max SNR	Uni-formity
N	825	1,522	135	0.2	6.72	NEMA	86.8	23.9	160.2	16.3%
A	825	1,522	135	16.8	6.41	Air	84.3	23.2	155.6	16.3%

Analysis of Uncombined Images

Measured Data					Calculated Results			
Ch	Mean	Max	Noise SD	Noise Type	Mean SNR	% of Mean	Max SNR	% of Max
1	508	1,289	6.16	Air	54.0	76%	137.1	100%
2	618	978	5.73	Air	70.7	100%	111.8	82%



Composites



Channel 1

Channel 2

RF Coil Performance Evaluation



Test Date: 10/24/2007
 Model: 100216
 Revision: A
 SN: 365
 # of Channels 6

Coil: CTL Phased Array

Mfg.: USA Inst.

Mfg. Date: 7/10/2007 Coil ID: 795

Phantom: CTL phantoms

Sequence	TR	TE	Plane	FOV	Nx	Ny	BW	NSA	Thickness	Gap
SE	500	25	S	40	256	256	10.4	1	5	-

Coil Mode: c Thoracic


TX gain: 185 R1: 12 R2: 28

Analysis of Test Image

Measured Data							Calculated Results			
Label	Mean	Max	Min	Back ground	Noise SD	Noise Type	Mean SNR	Normal-ized	Max SNR	Uni-formity
2007s	1,142	2,330	498	-0.9	17.04	NEMA	47.4	13.1	96.7	35.2%
2007i	1,771	3,357	1,037	-7.7	21.85	NEMA	57.3	15.8	108.7	47.2%
2006s	1,167	2,470	424	20.0	19.00	NEMA	43.4	12.0	91.9	29.3%
2006i	1,877	3,486	1,088	-0.5	25.63	NEMA	51.8	14.3	96.2	47.6%

USAI Protocol: _____

Test Images



RF Coil Performance Evaluation



Test Date: 10/24/2007
 Model: 100216
 Revision: A
 SN: 365
 # of Channels 6

Coil: CTL Phased Array

Mfg.: USA Inst.

Mfg. Date: 7/10/2007 Coil ID: 795

Phantom: CTL phantoms

Sequence	TR	TE	Plane	FOV	Nx	Ny	BW	NSA	Thickness	Gap
SE	300	20	S	40	256	128	6.91	1	5	-

Coil Mode: d Thoracic TX gain: 185 R1: 10 R2: 28

Analysis of Composite Image


Measured Data							Calculated Results			
Label	Mean	Max	Min	Back ground	Noise SD	Noise Type	Mean SNR	Normalized	Max SNR	Uniformity
N	1,136	1,947	612	-0.1	18.23	NEMA	44.1	4.9	75.5	47.8%
N	1,645	2,639	1,001	-0.9	19.39	NEMA	60.0	6.7	96.3	55.0%
A	1,136	1,942	611	58.8	18.64	Air	39.9	4.5	68.3	47.9%
A	1,646	2,648	999	58.8	18.64	Air	57.9	6.5	93.1	54.8%

Analysis of Uncombined Images


Measured Data					Calculated Results			
Ch	Mean	Max	Noise SD	Noise Type	Mean SNR	% of Mean	Max SNR	% of Max
1	935	1,857	17.09	Air	35.9	100%	71.2	74%
2	829	1,094	17.55	Air	31.0	86%	40.8	43%
3	722	2,208	15.11	Air	31.3	87%	95.8	100%

Simply Physics protocol.....

Composites



Channels



Channel 1

Channel 2

Channel 3

RF Coil Performance Evaluation



Test Date: 10/24/2007
 Model: 100216
 Revision: A
 SN: 365
 # of Channels 6

Coil: CTL Phased Array

Mfg.: USA Inst.

Mfg. Date: 7/10/2007 Coil ID: 795

Phantom: CTL phantoms

Sequence	TR	TE	Plane	FOV	Nx	Ny	BW	NSA	Thickness	Gap
SE	500	25	S	40	256	256	10.4	1	5	-

Coil Mode: e Lumbar

TX gain: 187 R1: 10 R2: 28


Analysis of Test Image

Measured Data							Calculated Results			
Label	Mean	Max	Min	Back ground	Noise SD	Noise Type	Mean SNR	Normal-ized	Max SNR	Uni-formity
Ns	1,337	3,214	465	-5.2	16.27	NEMA	58.1	16.0	139.7	25.3%
Ni	1,302	2,989	448	-0.3	15.70	NEMA	58.6	16.2	134.6	26.1%
As	1,342	3,219	474	53.4	16.07	Air	54.7	15.1	131.3	25.7%
Ai	1,302	2,993	449	52.5	15.91	Air	53.6	14.8	123.3	26.1%

USAI Protocol

There is little difference between last year and this year. (Maybe a little higher this year.)

Test Images



RF Coil Performance Evaluation



Test Date: 10/24/2007
 Model: 100216
 Revision: A
 SN: 365
 # of Channels 6

Coil: CTL Phased Array

Mfg.: USA Inst.

Mfg. Date: 7/10/2007 Coil ID: 795

Phantom: CTL phantoms

Sequence	TR	TE	Plane	FOV	Nx	Ny	BW	NSA	Thickness	Gap
SE	300	20	S	40	256	128	6.91	1	5	-

Coil Mode: f Lumbar TX gain: 188 R1: 10 R2: 28

Analysis of Composite Image


Measured Data							Calculated Results			
Label	Mean	Max	Min	Back ground	Noise SD	Noise Type	Mean SNR	Normalized	Max SNR	Uniformity
N	1,242	2,549	564	-5.2	16.90	NEMA	52.0	5.8	106.7	36.2%
N	1,243	2,466	591	-0.1	15.53	NEMA	56.6	6.4	112.3	38.7%
A	1,247	2,545	565	50.5	15.74	Air	51.9	5.8	106.0	36.3%
A	1,244	2,462	599	50.5	15.73	Air	51.8	5.8	102.6	39.1%

Analysis of Uncombined Images


Measured Data					Calculated Results			
Ch	Mean	Max	Noise SD	Noise Type	Mean SNR	% of Mean	Max SNR	% of Max
1	892	2,200	13.64	Air	42.9	100%	105.7	100%
2	729	898	14.40	Air	33.2	77%	40.9	39%
3	849	1,992	14.49	Air	38.4	90%	90.1	85%

Just a little lower than last year.....

Composites



Channels



Channel 1

Channel 2

Channel 3

RF Coil Performance Evaluation



Test Date: 10/24/2007
 Model: 100187
 Revision: B
 SN: 386
 # of Channels 3

Coil: Foot

Mfg.: USA Inst.

Mfg. Date: 1/1/2002 Coil ID: 447

Phantom: Foot

Sequence	TR	TE	Plane	FOV	Nx	Ny	BW	NSA	Thickness	Gap
SE	300	20	T	40	256	256	10.4	1	5	-

Coil Mode: Foot @ S30 A20

TX gain: 189 R1: 7 R2: 29


Analysis of Composite Image

Measured Data							Calculated Results			
Label	Mean	Max	Min	Back ground	Noise SD	Noise Type	Mean SNR	Normal-ized	Max SNR	Uni-formity
N	938	1,362	399	1.3	3.76	NEMA	176.4	48.6	256.2	45.3%
A	937	1,359	403	11.1	3.49	Air	175.9	48.5	255.2	45.7%


Analysis of Uncombined Images

Measured Data					Calculated Results			
Ch	Mean	Max	Noise SD	Noise Type	Mean SNR	% of Mean	Max SNR	% of Max
1	384	923	2.80	Air	89.9	92%	216.0	84%
2	530	1,390	3.54	Air	98.1	100%	257.3	100%
3	444	803	2.97	Air	98.0	100%	177.2	69%

Simply Physics Protocol.....
 Little better than last year.....



Composites



Channel 3

RF Coil Performance Evaluation



Test Date: 10/24/2007
 Model: 2280062
 Revision: _____
 SN: 905034YM5
 # of Channels 1

Coil: Head

Mfg.: USA Inst.

Mfg. Date: 2/1/2003 Coil ID: 241

Phantom: ACR Phantom


Sequence	TR	TE	Plane	FOV	Nx	Ny	BW	NSA	Thickness	Gap
SE	300	20	T	40	256	256	10.4	1	5	-

Coil Mode: Head

TX gain: 127 R1: 8 R2: 28

Analysis of Test Image

Measured Data							Calculated Results			
Label	Mean	Max	Min	Back ground	Noise SD	Noise Type	Mean SNR	Normal-ized	Max SNR	Uni-formity
N	1,062	1,140	1,013	-0.2	6.76	NEMA	111.1	30.6	119.3	94.1%
A	1,062	1,141	1,012	10.8	5.40	Air	128.9	35.5	138.5	94.0%



RF Coil Performance Evaluation



Test Date: 10/24/2007
 Model: 100214
 Revision: B
 SN: 322
 # of Channels 2

Coil: Knee - Large

Mfg.: USA Inst.

Mfg. Date: 3/1/2002 Coil ID: 243

Phantom: Knee bottle

Sequence	TR	TE	Plane	FOV	Nx	Ny	BW	NSA	Thickness	Gap
SE	300	20	T	25	256	256	10.4	1	5	-

Coil Mode: Knee Large

TX gain: 188 R1: 10 R2: 28


Analysis of Composite Image

Measured Data							Calculated Results			
Label	Mean	Max	Min	Back ground	Noise SD	Noise Type	Mean SNR	Normal-ized	Max SNR	Uni-formity
N	2,576	2,813	2,381	3.0	18.72	NEMA	97.3	68.7	106.3	91.7%
A	2,573	2,811	2,375	47.3	17.92	Air	94.1	66.4	102.8	91.6%


Analysis of Uncombined Images

Measured Data					Calculated Results			
Ch	Mean	Max	Noise SD	Noise Type	Mean SNR	% of Mean	Max SNR	% of Max
1	1,897	2,112	14.96	Air	83.1	100%	92.5	100%
2	1,570	1,756	18.43	Air	55.8	67%	62.4	67%

Simply Physics protocol - no gradwarp



Composites



Channel 1

Channel 2

RF Coil Performance Evaluation



Test Date: 10/24/2007
 Model: 100214
 Revision: B
 SN: 322
 # of Channels 2

Coil: Knee - Large

Mfg.: USA Inst.

Mfg. Date: 3/1/2002 Coil ID: 243

Phantom: Knee bottle

Sequence	TR	TE	Plane	FOV	Nx	Ny	BW	NSA	Thickness	Gap
SE	300	20	S	30	256	256	10.4	1	5	-

Coil Mode: Knee Large

TX gain: 188 R1: 8 R2: 29


Analysis of Composite Image

Measured Data							Calculated Results			
Label	Mean	Max	Min	Back ground	Noise SD	Noise Type	Mean SNR	Normal-ized	Max SNR	Uni-formity
N	1,885	2,740	963	-0.2	13.00	NEMA	102.5	50.2	149.1	52.0%
A	1,885	2,737	963	33.0	12.57	Air	98.3	48.1	142.7	52.1%


Analysis of Uncombined Images

Measured Data					Calculated Results			
Ch	Mean	Max	Noise SD	Noise Type	Mean SNR	% of Mean	Max SNR	% of Max
1	1,406	2,010	10.53	Air	87.5	100%	125.1	100%
2	1,210	1,807	12.88	Air	61.6	70%	91.9	73%

Simply Physics protocol - no gradwarp




Composites



Channel 1

Channel 2

RF Coil Performance Evaluation



Test Date: 10/24/2007
 Model: 100213
 Revision: B
 SN: 464
 # of Channels 2

Coil: Knee & Foot (small)

Mfg.: USA Inst.

Mfg. Date: 6/1/2005 Coil ID: 244

Phantom: Knee phantom

Sequence	TR	TE	Plane	FOV	Nx	Ny	BW	NSA	Thickness	Gap
SE	300	20	T	25	256	256	10.4	1	5	-

Coil Mode: Small Knee

TX gain: 188 R1: 8 R2: 28

Analysis of Composite Image


Measured Data							Calculated Results			
Label	Mean	Max	Min	Back ground	Noise SD	Noise Type	Mean SNR	Normal-ized	Max SNR	Uni-formity
N	1,130	1,265	1,007	0.1	6.67	NEMA	119.8	84.5	134.1	88.6%
A	1,130	1,264	1,008	16.2	6.15	Air	120.4	84.9	134.7	88.7%

Analysis of Uncombined Images

Measured Data					Calculated Results			
Ch	Mean	Max	Noise SD	Noise Type	Mean SNR	% of Mean	Max SNR	% of Max
1	953	1,095	6.06	Air	103.1	100%	118.4	100%
2	645	747	5.38	Air	78.6	76%	91.0	77%




Composites



Channel 1

Channel 2

RF Coil Performance Evaluation



Test Date: 10/24/2007
 Model: 100213
 Revision: B
 SN: 464
 # of Channels 2

Coil: Knee & Foot (small)

Mfg.: USA Inst.

Mfg. Date: 6/1/2005 Coil ID: 244

Phantom: Knee phantom

Sequence	TR	TE	Plane	FOV	Nx	Ny	BW	NSA	Thickness	Gap
SE	300	20	S	30	256	256	10.4	1	5	-

Coil Mode: Small Knee

TX gain: 187 R1: 7 R2: 29

Analysis of Composite Image

Measured Data							Calculated Results			
Label	Mean	Max	Min	Back ground	Noise SD	Noise Type	Mean SNR	Normal-ized	Max SNR	Uni-formity
N	764	1,241	320	-0.0	4.67	NEMA	115.7	56.7	187.9	41.0%
A	764	1,240	322	11.3	4.32	Air	115.9	56.8	188.1	41.2%

Analysis of Uncombined Images

Measured Data					Calculated Results			
Ch	Mean	Max	Noise SD	Noise Type	Mean SNR	% of Mean	Max SNR	% of Max
1	622	1,029	4.31	Air	94.6	100%	156.5	100%
2	460	730	3.72	Air	81.0	86%	128.6	82%



Composites



Channel 1

Channel 2

RF Coil Performance Evaluation



Test Date: 10/24/2007
 Model: 100217
 Revision: B
 SN: ?352
 # of Channels 2

Coil: Shoulder Phased Array

Mfg.: USA Inst.

Mfg. Date: 8/28/2002 Coil ID: 245

Phantom: Head TLT sphere

Sequence	TR	TE	Plane	FOV	Nx	Ny	BW	NSA	Thickness	Gap
SE	300	20	C	36	256	256	10.4	1	5	-

Coil Mode: Shoulder TX gain: 195 R1: 9 R2: 28


Analysis of Composite Image

Measured Data							Calculated Results			
Label	Mean	Max	Min	Back ground	Noise SD	Noise Type	Mean SNR	Normal-ized	Max SNR	Uni-formity
N	830	1,485	467	-0.9	3.44	NEMA	170.6	58.1	305.3	47.8%
A	831	1,485	468	8.7	3.30	Air	165.0	56.1	294.9	47.9%


Analysis of Uncombined Images

Measured Data					Calculated Results			
Ch	Mean	Max	Noise SD	Noise Type	Mean SNR	% of Mean	Max SNR	% of Max
1	650	1,081	3.16	Air	134.8	100%	224.2	90%
2	470	1,146	3.00	Air	102.7	76%	250.3	100%

Simply Physics Protocol



Composites




Channel 1

Channel 2

Appendix A: Magnet Homogeneity Field Maps


GE Ovation 0.35T - 3 central planes

Measured October 24, 2007




Axial

DIAMETER	MIN	MAX	RANGE	PPM	MEAN	STDEV
10	-43	41	85	5.7	-12.9	19.9
15	-59	80	140	9.5	-11.6	31.4
20	-80	131	211	14.3	-9.6	44.7
25	-105	189	294	19.9	-7.2	60.0
28	-128	234	362	24.5	-5.7	70.3
30	-148	276	424	28.6	-4.6	77.3



Coronal

DIAMETER	MIN	MAX	RANGE	PPM	MEAN	STDEV
10	1	33	32	2.2	20.3	5.6
15	-16	33	50	3.4	14.6	9.5
20	-39	33	73	4.9	6.8	14.5
25	-71	33	104	7.1	-3.1	20.9
28	-94	33	128	8.7	-10.1	25.4









Sagittal

DIAMETER	MIN	MAX	RANGE	PPM	MEAN	STDEV
10	-67	25	93	6.3	-30.1	22.3
15	-75	73	149	10.1	-26.5	34.4
20	-90	128	218	14.8	-21.6	48.3
25	-110	186	297	20.0	-15.4	64.0
28	-122	225	347	23.4	-11.0	74.7
30	-137	258	395	26.6	-7.9	82.2

Appendix A: Magnet Homogeneity Field Maps

GE Ovation 0.35T

Measured October 24, 2007



Axial

Coronal

Sagittal

H,A,L

80

40
















IsoCenter

40

-80

F,P,R

Note the labels on the contours are twice those of 2006



Axial

Coronal

Sagittal

H,A,L

80

40
















IsoCenter

40

-80


F,P,R

Note the labels on the contours are one half those of 2007




Appendix B: RF Slice Profiles and Crosstalk

Spin Echo
 TR/TE = 400/18
 nex = 2
 BW = 10.4 KHz
 Scan time: 3:25




Slice thickness as a function of slice gap




Appendix B: RF Slice Profiles and Crosstalk

Spin Echo - POMP
 TR/TE = 400/19
 BW = 12.5 KHz
 nex = 2
 Scan time: 3:25



Slice thickness as a function of slice gap



Coil Used: Head

Test Date: 10/24/2007

Sagittal Locator							
1	Length of phantom, end to end (mn 148± 2)	146.3	= calculated field				
		(SE 500/20)	(SE 2000/20)	(SE 2000/80)	(Site T1)	(Site T2)	
Slice Location #1		ACR T1	ACR PD	ACR T2	Site T1	Site T2	
2	Resolution ••••	0.9	0.9	0.9	1.0	1.0	
3	(1.10, 1.00, 0.90 mm) •	1.0	1.0	1.0	1.0	1.0	
4	Slice Thickness Top	52.1	51.3	47.1	52.3	52.8	
5	(fwhm in mm) Bottom	58.1	59.3	53.4	59.2	56.8	
6	Calculated value 5.0±0.7	5.49	5.50	5.00	5.55	5.47	
7	Wedge (mm) ■ = + ■ = -	2.4	2.8	2.6	2.5	2.4	
8	Diameter (mm) (190±2) ⊕	190.5	190.2	190.0	190.3	190.4	
9		188.7	188.7	188.6	188.6	188.3	
Slice Location #5							
10	Diameter (mm) (190±2) ⊕	190.2	189.9	189.7	190.1	190.2	
11		188.8	188.8	188.7	188.7	188.5	
12		189.9	189.9	189.7	190.1	190.0	
13		190.5	190.5	190.3	190.5	190.4	
Slice Location #7							
14	Signal Big ROI	1258	1316	849	1270	713	
15	(mean only) High	1342	1393	918	1346	771	
16	Low	1216	1275	819	1227	689	
17	Uniformity (>87.5%)	95.1%	95.6%	94.3%	95.4%	94.4%	
18	Background Noise Top	33.2 ± 17.36	44.9 ± 21.94	33.2 ± 16.26	19.7 ± 9.88	21.1 ± 11.33	
19		Bottom	33.3 ± 16.49	43.3 ± 21.24	33.3 ± 16.10	19.6 ± 9.52	20.2 ± 10.61
20		Left	27.4 ± 12.83	34.5 ± 16.71	31.5 ± 15.26	18.2 ± 9.38	16.9 ± 8.28
21		Right	27.8 ± 13.75	34.0 ± 16.75	30.5 ± 14.10	17.0 ± 8.96	15.7 ± 7.82
22	Ghosting Ratio (<2.5%)	0.4%	0.7%	0.3%	0.2%	0.6%	
23	SNR (no spec)	95	79	58	138	89	
Low Con Detectability							
24	Slice Location #8 1.4%	0	0	0	1	0	
25	Slice Location #9 2.5%	2	1	0	7	2	
26	Slice Location #10 3.6%	5	1	0	9	4	
27	Slice Location #11 5.1%	7	4	5	9	7	
28	Total # of Spokes (>=9)	14	6	5	26	13	
Slice Location #11							
29	Wedge (mm) ■ = + ■ = -	-4.4	-4.7	-4.3	-4.4	-3.8	
30	Slice Position Error	-6.8	-7.4	-6.9	-6.9	-6.2	

The net Slice position error fails ACR spec.....

Sequence parameters

Test Date: 10/24/2007

Coil Used: Head

Test ID 218



Study Description	Pulse Sequence (ETL)	TR (ms)	TE (ms)	FOV (cm)	Phase Sample Ratio	Number of Slices	Thickness (mm)	Slice Gap	NSA (Nex)	Freq Matrix	Phase Matrix	Band Width (kHz)	Scan Time (min:sec)
ACR T1	SE	500	20	25	1	11	5	5	1	256	256	8.93	2:09
ACR PD	Dual Echo SE	2000	20	25	1	11	5	5	1	256	256	15.6	8:32
ACR T2	Dual Echo SE	2000	80	25	1	11	5	5	1	256	256	8.93	8:32
Site T1	SE	500	16	24	1	11	5	5	4	256	256	12.5	8:32
Site T2	FSE(12)	4400	12	24	1	11	5	5	5	256	224	12.5	6:51

Magnet ID: 20


Coil ID: 241

TestID: 218


Sagittal Length



High Contrast Resolution




Slice Thickness



Upper=52.08
Lower=58.12
Slice Thickness=5.49





Slice Position - Inferior





Diff.= 2.38



Axial Diameters - #1




Axial Diameters - #5



Uniformity & Ghosting - #7




Slice Position - Superior




Diff.= -4.40


Low Contrast - #8




Low Contrast - #9




Low Contrast - #10




Low Contrast - #11




High Contrast Resolution




Slice Thickness




Slice Position - Inferior




Axial Diameters - #1







Axial Diameters - #5




Uniformity & Ghosting - #7




Slice Position - Superior




Low Contrast - #8




Low Contrast - #9



Low Contrast - #10




Low Contrast - #11



High Contrast Resolution




Slice Thickness



Upper=47.06
Lower=53.41
Slice Thickness=5.00




Slice Position - Inferior




Diff.= 2.58


Axial Diameters - #1




Axial Diameters - #5






Uniformity & Ghosting - #7




Slice Position - Superior




Diff.= -4.33




Low Contrast - #8




Low Contrast - #9




Low Contrast - #10




Low Contrast - #11



High Contrast Resolution




Slice Thickness



Upper=52.28
Lower=59.21
Slice Thickness=5.55




Slice Position - Inferior




Diff.= 2.54


Axial Diameters - #1



Axial Diameters - #5




Uniformity & Ghosting - #7




Max:1346 Min:1227 PIU: 95.4%



Slice Position - Superior




Diff.= -4.38




10/24/07 TR: 500 TE: 16.0




Low Contrast - #8




Low Contrast - #9




Low Contrast - #10




Low Contrast - #11



High Contrast Resolution





Slice Thickness



Upper=52.83
Lower=56.77
Slice Thickness=5.47




Slice Position - Inferior




Diff.= 2.35


Axial Diameters - #1




Axial Diameters - #5






Uniformity & Ghosting - #7




Slice Position - Superior




Diff.= -3.78




Low Contrast - #8




Low Contrast - #9



Low Contrast - #10



Low Contrast - #11



Appendix D: Explanation of RF Coil Testing Report

Introduction

The primary goal of RF coil testing is to establish some sort of base line for tracking coil performance over time. The most common measure is the Signal to Noise Ratio or SNR. In addition, we can look at overall signal uniformity, ghosting level (or better - lack of ghosting) and in the case of phased array coils we look at the SNR of each and every channel and at symmetry between channels. Unfortunately, there is no single best method for measuring SNR. Below I explain the different methods used and the rationale for each.

SNR

One needs to measure the signal in the phantom (either mean or peak or both) and then divide that by the background noise. Measuring the signal is fairly straightforward, the noise can be more problematic. The simplest method is to measure the standard deviation (SD) in the background 'air'. However, MRI images are the magnitude of complex data. The noise in the underlying complex data is Gaussian but it follows a Rician distribution when the magnitude is used. The true noise can be estimated by multiplying the measured SD by 1.526.

During the reconstruction process, most manufacturers perform various additional operations on the images, This could include geometric distortion correction, low pass filtering of the k-space data resulting in low signal at the edge of the images, RF coil intensity correction (PURE, CLEAR, SCIC, etc), and other processing during the combination of phased array data and parallel imaging techniques. All of these methods distort the background noise making it impossible to obtain an accurate (and reproducible) estimate of the image noise in the air region. The alternative is to use a method which I shall refer to as the NEMA (National Electrical Manufacturers Association) method. The signal in the phantom area is a sum of the proton signal and noise. Once the signal to noise ratio exceeds 5:1, the noise in the magnitude image is effectively Gaussian. To eliminate the proton signal, you acquire an image twice and subtract them. The measured SD in the phantom region should now be the true SD times the square root of 2. When determining the SNR using the NEMA method, calculate the mean signal of the average of the two source images then divide by $.7071 \times$ the SD measured in the same area as the mean signal.

Unfortunately, this doesn't always work. It is absolutely imperative that the RF channel scalings, both transmit and receive, be identical with both scans. Any ghosting in the system is not likely to repeat exactly for both scans and will cause a much higher SD. Finally, the phantom needs to be resting in place prior to the scan long enough for motion of the fluid to have died down. Depending on the size and shape of the phantom, this could take anywhere from 5 to 20 minutes.

One of the most common causes of ghosting is vibration from the helium cold-head. The best way to eliminate this artifact is to turn off the cold head, which will increase helium consumption. Because this vibration is periodic, the ghosting is usually of an $N/2$ nature. The affect inside the signal region of the phantom can be minimized by using a FOV that is twice the diameter of the phantom (measured in the PE direction.) If the noise is to be measured in the air, then be sure to NOT make measurements to either side of the phantom in the PE direction.

Scan parameters also significantly affect measured SNR. For most of the testing performed in this document I used a simple Spin Echo with a TR of 300, a TE of 20 and a slice thickness of 3mm and a receiver BW of 15.6 KHz. The FOV was varied depending on the size of the coil and the phantom used. All of the parameters used for each test can be found on each page immediately below the coil description.

Report Layout

Each page of this report lists the data from a single test. The top third of the page describes the coil and phantom information, followed by the scan parameters used. The middle third contains the numbers measured and calculated results. This section will contain one table if the coil being tested is a single channel coil (i.e. quadrature or surface coils) and two tables if it is a multi-channel phased array coil. The entries in the table will be described further below. The bottom section contains a few lines of comments (if necessary), a picture of the coil with the phantom as used for the testing and one or more of the images that were used for the measurements.

There is usually one image for each composite image measurement and one image for each separate channel measurement. Each image shows the ROI (red line) where the mean signal was measured and two smaller ROIs (green lines) where the signal minimum and maximum was found. In the top left corner of each image is the mean signal in the large ROI. The bottom left corner contains the large ROI's area (in mm²). The top right corner contains two numbers a mean and a standard deviation. If the NEMA method was used, then the top right corner will list the mean and SD of the large ROI (labeled ROI M and ROI_{sd}) applied to the subtraction image. If the noise was measured in the background air the the numbers are labeled Air M and AirSD.

Data Tables

The meaning of most of the entries in the data table are should be self evident with a few exceptions. The first column in each table is labeled "Label". In the composite analysis, this field may be empty or contain some sort of abbreviation to identify some aspect of the testing. Some possibilities are the letter N for NEMA, A for Air, L for Left, R for Right, C for CLEAR, NoC for No CLEAR. In the Uncombined Image table, the label usually contains the channel number or similar descriptor. The column labeled "Noise Type" will be either Air or SubSig which stands for Subtracted Signal, *i.e.* the NEMA method. Both tables contain a column for Mean SNR and Max SNR which are the Mean or Max signal divided by the SD of the noise scaled by either 1.526 (Air) or 0.7071 (NEMA).

Composite Image Table: The final two columns in this table are "Normalized" and "Uniformity". It can be rather difficult to compare the performance of different coils particularly if different scan parameters are used. (Of course, it's even more difficult from one scanner to another.) I have standardized most of my testing to use a spin echo with a TR/TE of 300/20msec and a thickness of 3 mm. The FOV changes to depending on the size of the phantom used although I try to use a FOV that is at least twice the diameter of the phantom as measured in the PE direction. For one reason or another, a change may be made in the scan parameters (either accidentally or intentionally such as turning on No Phase Wrap to eliminate aliasing, etc.). In order to make it easier to compare SNR values I calculate a "Normalized" SNR value. This value is theoretically what the SNR would be if a FOV of 30cm, 256x256 matrix, 1 average, receiver BW of 15.6 KHz and slice thickness of 3mm had been used. Obviously, the final number is affected by the T1/T2 values of the phantoms used as well as details of the coil and magnet field strength but it can be useful in certain situations.

The "Uniformity" value is defined by the ACR as $1 - (\max - \min) / (\max + \min)$. This is most important when looking at volume coils or for evaluating the effectiveness of surface coil intensity correction algorithms (such as PURE, CLEAR or SCIC).

Uncombined Image Table: This table has two columns labeled "% of Mean" and "% of Max". When analyzing multi-channel coils it is important to understand the relationship between the different channels, the inherent symmetry that usually exists between channels. In a 8 channel head or 4 channel torso phased array coil, all of the channels are usually have about the same SNR. These two columns list how the SNR (either Mean or Max) of each channel compares to the SNR of the channel with the maximum value.